# **Vibration Meter (Multi Channel)**





#### Vibration Standard

ISO/IS2373 M	Iotor Quality Standard According As Vibration Velocity				
Quality Rank	Rev (rpm)	H: high of shaft (mm) Maximum vibration velocity rms (mm/s)			
Rank		80 <h<132< td=""><td>132<h<225< td=""><td>225<h<400< td=""></h<400<></td></h<225<></td></h<132<>	132 <h<225< td=""><td>225<h<400< td=""></h<400<></td></h<225<>	225 <h<400< td=""></h<400<>	
Normal	600~3600	1.8	2.8	4.5	
Cood (D)	600~1800	0. 71	1. 12	1.8	
Good (R)	1800~3600	1. 12	1.8	2. 8	
Erroellont (C)	600~1800	0. 45	0. 71	1. 12	
Excellent (S)	1800~3600	0. 71	1. 12	1.8	

Model: VM-6380-2 (2 Channels) VM-6380-3 (3 Channels)

#### **Applications**

Used for measuring periodic motion, to check the imbalance and deflecting of moving machinery. Specifically designed for present measuring various mechanical vibration. So as to provide the data for the quality control, run time and equipment upkeep.

- \* VM-6380-2 can not only show 2 same parameters in one display for 2 position measurement, but also can show 3 different parameters of velocity, acceleration and displacement in 1 display.
- \* VM-6380-3 can not only show 3 same parameters in one display for 3 position measurement, but also can show 3 different parameters of velocity, acceleration and displacement in 1 display.

#### **Features**

- \* In accordance with ISO 2954, used for periodic measurements, to detect out-of-balance, misalignment and other mechanical faults in rotating machines.
- \* Specially designed for easy on site vibration measurement of all rotating machinery for quality control, commissioning, and predictive maintenance purposes.
- \* Individual high quality accelerometer for accurate and repeatable measurements.
- \* Wide frequency range (10Hz~10kHz) in acceleration mode.
- \* Optional headphones for use as electronic stethoscope.
- \* Use RS-232 data output to connect with PC.
- \* Provide Bluetooth data output choice.

### DIGITAL INSTRUMENT

## Specifications

Model		VM-6380-2	VM-6380-3	
Sensor		2 Piezoelectric Transducer	3 Piezoelectric Transducer	
Measuring Range Acceleration		0.1~400 m/s² 0.3~1312 ft/s² 0.0~40 g Equivalent Peak		
Velocity		0.01~400 mm/s 0.04~16.0 inch/s True RMS		
	Displacement	0.001~4.0 mm 0.04~160.0	mil Equivalent Peak-peak	
Frequency Range	Acceleration	10Hz~	10Hz∼10kHz	
Velocity		10Hz~1kHz		
Displacement		10Hz~1kHz		
Accuracy		5% of Reading + 2 digits		
Operating Temperature		0~50	0 ℃	
Conditions Humidity		<90 %RH		
Power Supply		4x1.5V AAA (UM-4) Battery		
Dimensions		140x73x35mm		
Weight		415 g (Not Including Batteries)		
Standard Accessories		Main Unit		
		Piezoelectric Transducers		
		Powerful Magnetic Base		
		Probe (Cone) & I	Probe (Spherical)	
		Carrying (	Case (B04)	
		Manua	l Book	
Optional Accessories		Headset		
		RS-232C Data Cable with Software		
		Bluetooth Data Adapter with Software		

## Accessories

Accessories	Diagram	Using Situations	Using Method
Piezoelectric Transducer		General vibration parameters measurement of objects.	Be used with Powerful Rare Earth Magnet & Stinger Probe.
Rare Earth Magnet		Magnetic objects with flat surface, roughness of less than Ra1.6, acceleration $\leq$ 20m/s.	connect the vibration sensor with Rare Earth Magnet with the M5 bolt included. And then place the Rare Earth Magnet to the object to be tested.
Stinger Probe (Ball / Cone)	<del></del>	Frequency is less than 1KHz and vibration energy is not small.	Connect the needle to the sensor directly by using probe groupware.